

Flow Transmitter / Screw Volumeter LABO-VHS-I / U / F / C



- Measures and monitors viscous media (oil) 1.4..2500 l/min
- Connection G 1..G 2¹/₂
- Very low dependence on viscosity
- Can be used up to 40,000 mm²/s (cSt)
- 0..10 V, 4..20 mA, frequency/pulse output, completely configurable
- Light and compact device (aluminium housing)
- Operation and measurement possible with forward and reverse flow
- For cost-sensitive applications

Characteristics

The VHS flow transmitter measures the flow using the volumetric principle, and is suitable for fluid, viscous, lubricant media (e.g. lubricating oil). If the material for the VHS is selected appropriately, aqueous fluids such as soaps, pastes, and emulsions with non-abrasive characteristics can also be measured, as long as they have sufficient lubricity. Because of the volumetric functioning principle, the device is almost completely independent of viscosity.

The VHS system consists of two interlacing screws which run in opposite directions, driven by the flowing medium. A magnetically pre-tensioned Hall sensor positioned outside the flow space detects the screw flanks, and creates a frequency signal proportional to the flow. Here, every pulse corresponds to a specific measured volume. There are no magnets in the flow space.

The LABO-XXX-I/U/F/C electronics make various output signals available:

- Analog signal 0/4...200 mA (LABO-VHS-I)
- Analog signal 0/2..10 V (LABO-VHS-U)
- Frequency signal (LABO-VHS-F) or
- Value signal Pulse / x Litres (LABO-VHS-C)

A model with switching output is also available (see separate datasheet). If desired, the range end value can be set to the currently existing flow using "teaching".

Technical data						
Sensor	screw volumeter					
Nominal width	DN 2565					
Process	female thread G 1G 21/2					
connection						
Metering ranges	see table "Ranges and we	ights"				
Measurement	±1 % of the measured valu					
accuracy	(cSt) of 1 %100 % nominal working range					
Repeatability	(see also diagrams in upstream pages) ±0.25 %					
Pressure	Connection SAE PN					
resistance	Construction material flange					
	Aluminium	without	160			
	Aluminium	with	350			
	Steel	without	350			
	Steel	with	350			
	others available on reques	t				
Pressure loss	see diagram in upstream p	ages				
Medium	oil or non-aggressive,					
	self-lubricating fluids					
Medium	-25+80 °C (150 °C available on request)					
temperature	<u> </u>					
Materials medium-contact	(special materials available on request):					



1.	Body	Aluminium 6082 and	odised
2.	Connections:	Aluminium 6082 and	odised or steel
3.	Main	Stahl 35SMnPb10 U	JNI 4838-80
:	screw		
	Subsidiary	GHISA GJL-250 EN	11561
	screw		
	Ball bearing	Steel	
	Ball bearing	Steel	
7.	Screws	Galvanised steel	
8.	O-ring	NBR	
9.	Seeger ring	Steel	
10.	Seeger ring	Steel	
11. (O-ring	NBR	
	SAE	ASTM A216WCB	
'	connection		
13.	SAE flange	ASTM A216WCB	
14.	O-ring	NBR	
15.	Screws	Galvanised steel	
16.	Sensor	Aluminium 6082 and	odised
	spacer		
l	erials, non-	Sensor tube:	CW614N nickelled
med	lium-contact	Adhesive:	epoxy resin
		Flange bolts:	stainless steel
Sup	ply	1030 V DC at volta	age output 10 V:
volt	age	1530 V DC	
Pow		< 1 W (for no-load of	outputs)
con	sumption		




Output data:	all outputs are resistant to short circuits and reversal polarity protected
Current output:	420 mA (020 mA available on request)
Voltage output:	010 V (210 V available on request) output current max. 20 mA
Frequency output:	transistor output "push-pull" I _{out} = 100 mA max.
Pulse output:	transistor output "push-pull" l _{out} = 100 mA max. Pulse width 50 ms Pulse per volume is to be stated
Display	yellow LCD shows operating voltage (LABO-VHS-I / U) or output status (LABO-VHS-F / C) or (rapid flashing = programming)
Electrical connection	for round plug connector M12x1, 4-pole
Ingress protection	IP 67
Weight	see table "Ranges and weights"
Conformity	CE


Signal output curves

Value x = Begin of the specified range = not specified range


Current output

Voltage output





Frequency output



 $f_{\text{\tiny max}}$ selectable in the range of up to 2000 Hz


Other characters on request.

Ranges and weights

● = Standard ○ = Option

G	G DN		N Metering		Types	Q _{max}	Weights					
			range 1100 % Q _{nom}	pulse		recommended	Body with aluminium connections	Body with steel connections	SAE Flanges (Weight per pair)			
			l/min	cm ³		l/min	kg	kg	kg			
G 1	DN 25	•	1.4 140	13.10	LABO-VHS-0250140	200	3.44	4.76	5.76			
G 1 ¹ / ₄	DN 32	•	3.5 350	29.00	LABO-VHS-0320350	500	6.35	8.50	9.55			
G 1 ¹ / ₂	DN 40	0	5.5 550	48.58	LABO-VHS-0400550	800	10.50	13.60	15.10			
		•	8.0 800	72.00	LABO-VHS-0400800	1200	14.20	18.50	18.80			
G 2	DN 50	0	10.01000	103.63	LABO-VHS-0501000	1600	20.70	27.70	30.30			
		•	15.01500	133.00	LABO-VHS-0501500	2200	25.00	33.20	34.60			
G 2 ¹ / ₂	DN 65	•	25.02500	238.82	LABO-VHS-0652500	3800	42.70	56.10	60.70			

Wiring



Before the electrical installation, it must be ensured that the supply voltage corresponds to the data sheet.

It is recommended to use shielded wiring. The push-pull output) of the frequency or pulse output version can as desired be switched as a PNP or an NPN output.

Connection example: PNP NPN





Dimensions

● = Standard ○ = Option							VHS	.GAO			VHS	GAX			
G	DNrange		x1	L1	ØD	SW	Α	М	x2	В	С	L2	Н	Е	F
G 1	0250140	•	20	220	88	78	49.0	12	20	57.1	27.8	324	52	80	69
G 1 ¹ / ₄	0320350	•	22	285	103	-	55.0	14	22	66.7	31.6	381	48	94	77
G 1 ¹ / ₂	0400550	Ō	24	332	122	-	58.8	16	24	79.4	36.5	448	58	106	89
	0400800	•		340	138	-	66.5					456			
G 2	0501000	0	33	396	155	-	71.0	20	35	96.8	44.4	544	74	135	116
	0501500	•		405	168	-	77.3					553			
G 2 ¹ / ₂	0652500	•	35	475	203	-	86.0	24	42	123.8	58.7	633	79	166	150

VHS-..GAX VHS-..GAX VHS-..GAX

 $M12 \times 1$

SAE adapter for convenient installation and for increased stability to pressure! (350 bar)

Handling and operation

Installation

Any flow direction is possible during installation. Ensure that pipework is clean. Flush before installation. A 30 μm mesh filter should be used.

The use of SAE flanges enables the sensor to be installed and removed more easily, and increases the stability to pressure to 350 bar for every connection material.

It is possible to replace the electronics during operation, and this presents no danger to the fitter. The sensor does not go into the flow space.

Note

The metering range end value can be programmed by the user via "teaching". Requirement for programmability must be stated when ordering, otherwise the device cannot be programmed.

The ECI-1 device configurator with associated software is available as a convenient option for programming all parameters by PC, and for adjustment. The teaching option is not available for the pulse output version.



Operation and programming

The teaching process can be carried out by the user as follows:


- The flow rate to be set is applied to the device.
- Apply an impulse of at least 0.5 seconds and max. 2 seconds duration to pin 2 (e.g. via a bridge to the supply voltage or a pulse from the PLC), in order to accept the measured value.
- When teaching has been successfully completed, pin 2 should be connected to 0 V, so as to prevent unintended programming.

The devices have a yellow LED which flashes during the programming pulse. During operation, the LED serves as an display for operating voltage (for analog output) or of switching status (for frequency or pulse output).

In order to avoid the need to transit to an undesired operating status during the teach-in, the device can be provided ex-works with a teach-offset.

The teach-offset point is added to the currently measured value before saving. The offset point can be positive or negative. Example: The end of the metering range should be set to 80 %. However, only 60 % can be achieved without problem. In this case, the device would be ordered with a "teach-offset" of +20°%... At 60 % in the process, a value of 80 % would then be stored during "teaching". If necessary, a far greater number of parameters can also be programmed using the ECI-1 device configurator.

Ordering code



O=Option

1.	Nominal	width					
	025	DN 25 - G 1			_		
	032	DN 32 - G 1 ¹ / ₄					
	040	DN 40 - G 1 ¹ / ₂					
	050	DN 50 - G 2]		
	065	DN 65 - G 2 ¹ / ₂					
2.		connection					
	G	female thread					
3.	Connecti	on material					
		AL connection, anodised					
	Α	(160 bar, in combination with					
	2 0	SAE flange: 350 bar)					
	S O	Connection, steel (350 bar)					
4.	Additiona						
	Х	SAE flange, steel (350 bar)					
	0	no SAE flange (pressure resistance depends on the					
		connection material)					
5.	Body ma	terial					
	Α	anodised aluminium					
6.	Metering	range					
	0140	1.4 140 l/min					•
	0350	3.5 350 l/min				•	
	0550 O	5.5 550 l/min			•		
	0800	8.0 800 l/min			•		
	1000 O	10.01000 I/min		•			
	1500	15.01500 I/min		•			
	2500	25.02500 I/min	•				
7.	Seal mate	erial					
	N	NBR					
	V O	FKM					
8.	Connecti	on for					
	E	electronics					
9.	For nomi	nal width					
	025	DN 25 - G 1					•
	032	DN 32 - G 1 ¹ / ₄				•	
	040	DN 40 - G 1 ¹ / ₂			•		
	050	DN 50 - G 2		•			
	065	DN 65 - G 2 ¹ / ₂	•				
10.	Signal ou	•					
	I	current output 420 mA					
	U	voltage output 010 V					
	F	frequency output					
	С	pulse output					
11.	Program						
	N	cannot be programmed (no teaching))				
	P O	programmable (teaching possible)					
12.		connection	_				
4.5	S	for round plug connector M12x1, 4-pe	ole				
13.							
	Optional H O	150 °C with electronics separated by					_



Required ordering information	
For LABO-VHS-F: Output frequency at full scale Maximum value: 2.000 Hz	Hz
For LABO-VHS-C: For the pulse output version, the volume (with unit) which will correspond to one pulse must be	
Volume per pulse (numerical value)	
Volume per pulse (unit)	
Options	
Special range for analog output: <= metering range (standard=metering range)	[]]I/min
Special range for frequency output: <= metering range (standard=metering range)	[]]I/min
Power-On delay period (099 s) (time after applying power during which the outputs are not activated or set to defined values)	s

Further options available on request.

Accessories

- Cable/round plug connector (KB...) see additional information "Accessories"
- converter / counter OMNI-TA
- Device configurator ECI-1

P+90 262 290 20 20 **F**+90 262 290 20 21